EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET



Model: DCA-180SSK3

The engine used in this generator set is certified to comply with United States EPA Tier 1 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

FNG	INE	DV-	ГΛ
CING		DΑ	М

Model: KOMATSU SA6D108E Bore: 4.30 in. (108 mm)

Type: 4-Cycle, In-Line, 6-Cylinder, Diesel Stroke: 5.10 in. (130 mm)

Aspiration: Turbocharged, Aftercooled Displacement: 436 cid (7.1 liters)

Compression Ratio: 17:1

PERFORMANCE DATA	STANDBY	<u>PRIME</u>
SAE Gross HP @ 1800 RPM (60 Hz)	253	224
Rated Load Fuel Consumption (gal/Hr)	11.1	9.9
Rated Load Exhaust Gas Flow (cfm)	1165	1095
Rated Load Exhaust Gas Temperature (F)	892	770

United States EPA - Mobile Off-Highway Tier I Limits - ≥174 BHP- ≤301 BHP				
Criteria Pollutant	Emission Requirements	Certified Engine Emissions		
NOx (Oxides of Nitrogen as NO2)	6.90 gr/bhp-hr	5.29 gr/bhp-hr		
HC (Total Unburned Hydrocarbons)	0.97 gr/bhp-hr	0.22 gr/bhp-hr		
CO (Carbon Monoxide)	8.50 gr/bhp-hr	0.45 gr/bhp-hr		
PM (Particulate Matter)	0.40 gr/bhp-hr	0.19 gr/bhp-hr		

EPA Engine Family: 2KLXL7.15CCI

EPA Certificate of Conformance: KLX-NR6-02-04

Effective Date: Year 2002

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.