

# EXHAUST EMISSION DATA SHEET

## MQ POWER GENERATOR SET

Model: DCA-220SSK



The engine used in this generator set is certified to comply with United States EPA Tier 1 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

### ENGINE DATA

Model:	KOMATSU	S6D125E	Bore:	4.90 in.	(125 mm)
Type:	4-Cycle, In-Line, 6-Cylinder, Diesel		Stroke:	5.90 in.	(150 mm)
Aspiration:	Turbocharged, Aftercooled		Displacement:	674 cid	(11 liters)
			Compression Ratio:	17:1	

### PERFORMANCE DATA

### STANDBY

### PRIME

SAE Gross HP @ 1800 RPM (60 Hz)	316	283
Rated Load Fuel Consumption (gal/Hr)	13.7	12.3
Rated Load Exhaust Gas Flow (cfm)	1554	1412
Rated Load Exhaust Gas Temperature (F)	921	824

### United States EPA - Mobile Off-Highway Tier 1 Limits - $\geq 302$ BHP - $\leq 602$ BHP

Criteria Pollutant	Emission Requirements		Certified Engine Emissions	
NOx (Oxides of Nitrogen as NO <sub>2</sub> )	6.90	gr/bhp-hr	6.30	gr/bhp-hr
HC (Total Unburned Hydrocarbons)	0.97	gr/bhp-hr	0.20	gr/bhp-hr
CO (Carbon Monoxide)	8.50	gr/bhp-hr	0.30	gr/bhp-hr
PM (Particulate Matter)	0.40	gr/bhp-hr	0.20	gr/bhp-hr

EPA Engine Family: YKLXL11.0DB1  
EPA Certificate of Conformance: KLX-NRCI-00-08  
Effective Date: Year 2000

*Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.*