EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET



Model: DCA-220SSK3

The engine used in this generator set is certified to comply with United States EPA Tier 1 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

FNG	INE	DV-	ГΛ
CING		DΑ	М

Model: KOMATSU S6D125E Bore: 4.90 in. (125 mm)

Type: 4-Cycle, In-Line, 6-Cylinder, Diesel Stroke: 5.90 in. (150 mm)

Aspiration: Turbocharged, Aftercooled Displacement: 674 cid (11 liters)

Compression Ratio: 17:1

PERFORMANCE DATA	<u>STANDBY</u>	<u>PRIME</u>
SAE Gross HP @ 1800 RPM (60 Hz)	316	283
Rated Load Fuel Consumption (gal/Hr)	13.7	12.3
Rated Load Exhaust Gas Flow (cfm)	1554	1412
Rated Load Exhaust Gas Temperature (F)	921	824

United States EPA - Mobile Off-Highway Tier 1 Limits - ≥302 BHP- ≤602 BHP				
Criteria Pollutant	Emission Requirements	Certified Engine Emissions		
NOx (Oxides of Nitrogen as NO2)	6.90 gr/bhp-hr	6.26 gr/bhp-hr		
HC (Total Unburned Hydrocarbons)	0.97 gr/bhp-hr	0.37 gr/bhp-hr		
CO (Carbon Monoxide)	8.50 gr/bhp-hr	0.52 gr/bhp-hr		
PM (Particulate Matter)	0.40 gr/bhp-hr	0.17 gr/bhp-hr		

EPA Engine Family: 2KLXL11.0DB1

EPA Certificate of Conformance: KLX-NR6-02-07

Effective Date: Year 2002

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.