

EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET

Model: DCA-25SSIU3



The engine used in this generator set is certified to comply with United States EPA Tier 4i and CARB Mobile Off-Highway emission regulations.

ENGINE DATA

Manufacturer: ISUZU	Bore: 3.35 in. (85 mm)
Model: 4LE2	Stroke: 3.78 in. (96 mm)
Type: 4-Cycle, In-Line, 4-cylinder, Diesel	Displacement: 133 cid (2.18 liters)
Aspiration: Naturally Aspirated. Direct Injection	Compression Ratio: 18:1

PERFORMANCE DATA

SAE Gross HP @ 1800 RPM (60 Hz)	34
Rated Load Fuel Consumption (gal/Hr)	1.66
Rated Load Exhaust Gas Flow (cfm)	152
Rated Load Exhaust Gas Temperature (°F)	1004

United States EPA - Mobile Off-Highway Tier 4i Limits - 25.5 ≤ BHP ~ < 49.6 BHP

Criteria Pollutant	Emission Requirements		Certified Engine Emissions	
NOx (Oxides of Nitrogen as NO2)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
HC (Total Unburned Hydrocarbons)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
NOx + HC (Combined)	5.59	gr/bhp-hr	4.92	gr/bhp-hr
CO (Carbon Monoxide)	4.10	gr/bhp-hr	1.49	gr/bhp-hr
PM (Particulate Matter)	0.22	gr/bhp-hr	0.19	gr/bhp-hr

EPA Engine Family:	CSZXL02.2VNB
EPA Certificate of Conformance:	CSZXL02.2VNB-007
ARB Executive Order:	U-R-006-0361
Effective Date:	Model Year 2012

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
2012 MODEL YEAR
CERTIFICATE OF CONFORMITY
WITH THE CLEAN AIR ACT OF 1990**

**OFFICE OF TRANSPORTATION
AND AIR QUALITY
ANN ARBOR, MICHIGAN 48105**

Certificate Issued To: Isuzu Motors Limited (U.S. Manufacturer or Importer)	Effective Date: 09/16/2011	 Karl J. Simon, Director Compliance and Innovative Strategies Division	Issue Date: 09/16/2011
Certificate Number: CSZXL02.2VNB-007	Expiration Date: 12/31/2012		Revision Date: N/A


Model Year: 2012	Mobile/Stationary Indicator: Mobile
Manufacturer Type: Original Engine Manufacturer	Emissions Power Category: 19<=KW<37
Engine Family: CSZXL02.2VNB	Fuel Type: Diesel
	After Treatment Devices: No After Treatment Devices Installed
	Non-after Treatment Devices: Engine Design Modification


Pursuant to Section 213 of the Clean Air Act (42 U.S.C. section 7547) and 40 CFR Part 1039, and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following engines, by engine family, more fully described in the documentation required by 40 CFR Part 1039 and produced in the stated model year.

This certificate of conformity covers only those new compression-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 1039 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 1039.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 1039. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 1039.

This certificate does not cover engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.



 AIR RESOURCES BOARD	ISUZU MOTORS LIMITED	EXECUTIVE ORDER U-R-006-0361
		New Off-Road Compression-Ignition Engines

Pursuant to the authority vested in the Air Resources Board by Sections 43013, 43018, 43101, 43102, 43104 and 43105 of the Health and Safety Code; and

Pursuant to the authority vested in the undersigned by Sections 39515 and 39516 of the Health and Safety Code and Executive Order G-02-003;

IT IS ORDERED AND RESOLVED: That the following compression-ignition engines and emission control systems produced by the manufacturer are certified as described below for use in off-road equipment. Production engines shall be in all material respects the same as those for which certification is granted.

MODEL YEAR	ENGINE FAMILY	DISPLACEMENT (liters)	FUEL TYPE	USEFUL LIFE (hours)
2012	CSZXL02.2VNB	2.2	Diesel	5,000
SPECIAL FEATURES & EMISSION CONTROL SYSTEMS			TYPICAL EQUIPMENT APPLICATION	
Mechanical Direct Injection			Generator Set	

The engine models and codes are attached.

The following are the exhaust certification standards (STD) and certification levels (CERT) for hydrocarbon (HC), oxides of nitrogen (NO_x), or non-methane hydrocarbon plus oxides of nitrogen (NMHC+NO_x), carbon monoxide (CO), and particulate matter (PM) in grams per kilowatt-hour (g/kW-hr), and the opacity-of-smoke certification standards and certification levels in percent (%) during acceleration (Accel), lugging (Lug), and the peak value from either mode (Peak) for this engine family (Title 13, California Code of Regulations, (13 CCR) Section 2423):

RATED POWER CLASS	EMISSION STANDARD CATEGORY		EXHAUST (g/kW-hr)					OPACITY (%)		
			HC	NO _x	NMHC+NO _x	CO	PM	ACCEL	LUG	PEAK
19 ≤ kW < 37	Tier 4 - Interim	STD	N/A	N/A	7.5	5.5	0.30	N/A	N/A	N/A
		CERT	--	--	6.6	2.0	0.25	--	--	--

BE IT FURTHER RESOLVED: That for the listed engine models, the manufacturer has submitted the information and materials to demonstrate certification compliance with 13 CCR Section 2424 (emission control labels), and 13 CCR Sections 2425 and 2426 (emission control system warranty).

Engines certified under this Executive Order must conform to all applicable California emission regulations.

This Executive Order is only granted to the engine family and model-year listed above. Engines in this family that are produced for any other model-year are not covered by this Executive Order.

Executed at El Monte, California on this 1 day of September 2011.


 Annette Hebert, Chief
 Mobile Source Operations Division