EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET



Model: DCA-25SSIU

The engine used in this generator set is certified to comply with United States EPA Tier 1 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

ENGINE	DATA
---------------	------

Model: ISUZU C240 Bore: 3.39 in. (86 mm)

Type: 4-Cycle, In-Line, 4-Cylinder, Diesel Stroke: 4.02 in. (102 mm)

Aspiration: Naturally Aspirated Displacement: 144 cid (4.5 liters)

Compression Ratio: 20:1

PERFORMANCE DATA	STANDBY	<u>PRIME</u>
SAE Gross HP @ 1800 RPM (60 Hz)	36	31
Rated Load Fuel Consumption (gal/Hr)	1.9	1.7
Rated Load Exhaust Gas Flow (cfm)	160	160
Rated Load Exhaust Gas Temperature (F)	753	718

United States EPA - Mobile Off-Highway Tier I Limits - ≥25 BHP- ≤48 BHP			
Criteria Pollutant	Emission Requirements	Certified Engine Emissions	
NOx (Oxides of Nitrogen as NO2)	(7.08)* gr/bhp-hr	(3.88)* gr/bhp-hr	
HC (Total Unburned Hydrocarbons)	(NOx + HC)* Combined	(NOx + HC)* Combined	
CO (Carbon Monoxide)	4.10 gr/bhp-hr	1.04 gr/bhp-hr	
PM (Particulate Matter)	0.59 gr/bhp-hr	0.15 gr/bhp-hr	

EPA Engine Family: 2SZXL02.4YNC

EPA Certificate of Conformance: SZX-NR3-02-14

Effective Date: Year 2002

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.