## **EXHAUST EMISSION DATA SHEET**

## **MQ POWER GENERATOR SET**

## Model: DCA-400SSK



## The engine used in this generator set is certified to comply with United States EPA Tier 2 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

ENGINE DATA							
Model:	KOMATSU		SA6D140AE		Bore:	5.50 in.	(140 mm)
Туре:	4-Cycle,	In-Line,	6-Cylinder,	Diesel	Stroke:	6.50 in.	(165 mm)
Aspiration: Turbocharged, After			ercooled		Displacement:	930 cid	(15 liters)
					Compression F	Ratio:	16:1
PERFORMANCE DAT	<u>ST</u>	ANDBY	PRIME				
SAE Gross HP @ 1800 RPM (60 Hz)				560	490		
Rated Load Fuel Consumption (gal/Hr)				27.3	24.3		
Rated Load Exhaust Gas Flow (cfm)				2542	2436		
Rated Load Exhaust Gas Temperature (F)				1013	853		
United States EPA - Mobile Off-Highway Tier 2 Limits - ≥302 BHP - ≤602 BHP							
Criteria Pollutant		Em	Emission Requirements		Certified Engine Emissions		
NOx (Oxides of Nitrogen as	NO2)	(4.77)	)* gr/bhp-h	r	(4.47)*	gr/bhp-hr	
HC (Total Unburned Hydrocarbons) (I		(N	(NOx + HC)* Combined		(NOx + HC)* Combined		
CO (Carbon Monoxide) 8		8.50	gr/bhp-h	r	0.29	gr/bhp-hr	
PM (Particulate Matter)		0.40	gr/bhp-h	r	0.09	gr/bhp-hr	
EPA Engine Family: 1KLXL15.2EC3							
EPA Certificate of Conforma	ance:	KLX-NF	RCI-01-01				

Effective Date: Year 2001

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.