EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET

Model: DCA-400SSK3



The engine used in this generator set is certified to comply with United States EPA Tier 2 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

ENGINE DATA							
Model:	KOMATSU	SA6D14	SA6D140AE		5.50 in.	(140 mm)	
Туре:	4-Cycle, In-Line	ə, 6-Cylinder,	Diesel	Stroke:	6.50 in.	(165 mm)	
Aspiration:	ftercooled		Displacement:	930 cid	(15 liters)		
				Compression Ratio: 16:1		16:1	
PERFORMANCE DATA		<u>ST</u>	STANDBY		PRIME		
SAE Gross HP @ 1800 RPM (60 Hz)			560			490	
Rated Load Fuel Consumption (gal/Hr)			27.3	24.3			
Rated Load Exhaust Gas Flow (cfm)			2542	2436			
Rated Load Exhaust Gas Te		1013	853				
United States EPA - Mobile Off-Highway Tier 2 Limits - ≥302 BHP- ≤602 BHP							
Criteria Pollutant	E	Emission Requirements		Certified	Certified Engine Emissions		
NOx (Oxides of Nitrogen as	NO2) (4.7	77)* gr/bhp-h	ir	(4.47)*	gr/bhp-hr		
HC (Total Unburned Hydroc	arbons)	(NOx + HC)* Combined		(NOx + HC)* Combined			
CO (Carbon Monoxide)	8.	50 gr/bhp-h	ir	0.37	gr/bhp-hr		
PM (Particulate Matter)	0.	40 gr/bhp-h	ır	0.12	gr/bhp-hr		

EPA Certificate of Conformance: KLX-NR7-02-28 Effective Date: Year 2002

EPA Engine Family:

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.

2KLXL15.2EC3