

# EXHAUST EMISSION DATA SHEET

## MQ POWER GENERATOR SET

Model: DCA-400SSK3



The engine used in this generator set is certified to comply with United States EPA Tier 2 and CARB Mobile Off-Highway emission regulations when tested per ISO 8178 D2.

### ENGINE DATA

Model:	KOMATSU SA6D140AE	Bore:	5.50 in. (140 mm)
Type:	4-Cycle, In-Line, 6-Cylinder, Diesel	Stroke:	6.50 in. (165 mm)
Aspiration:	Turbocharged, Aftercooled	Displacement:	930 cid (15 liters)
		Compression Ratio:	16:1

### PERFORMANCE DATA

SAE Gross HP @ 1800 RPM (60 Hz)	560
Rated Load Fuel Consumption (gal/Hr)	20.4
Rated Load Exhaust Gas Flow (cfm)	2542
Rated Load Exhaust Gas Temperature (F)	1013

### United States EPA - Mobile Off-Highway Tier 2 Limits - $\geq 302$ BHP - $\leq 602$ BHP

Criteria Pollutant	Emission Requirements	Certified Engine Emissions
NOx (Oxides of Nitrogen as NO <sub>2</sub> )	(4.77)* gr/bhp-hr	(4.47)* gr/bhp-hr
HC (Total Unburned Hydrocarbons)	(NOx + HC)* Combined	(NOx + HC)* Combined
CO (Carbon Monoxide)	2.61 gr/bhp-hr	0.37 gr/bhp-hr
PM (Particulate Matter)	0.15 gr/bhp-hr	0.12 gr/bhp-hr

EPA Engine Family: 3KLXL15.2EC3  
EPA Certificate of Conformance: KLX-NR7-03-19  
Effective Date: Year 2003

*Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.*