

EXHAUST EMISSION DATA SHEET

MQ POWER GENERATOR SET

Model: DCA10SPXU4C



The engine used in this generator set is certified to comply with United States EPA Tier 4 and CARB Mobile Off-Highway emission regulations.

ENGINE DATA

Manufacturer: KUBOTA	Bore: 3.26 in. (83 mm)
Model: D1503	Stroke: 3.63 in. (92.4 mm)
Type: 4-Cycle, In-Line, 3-Cylinder, Diesel	Displacement: 91 cid (1.499 liters)
Aspiration: Naturally Aspirated, Indirect Injection	Compression Ratio: 21.6:1

PERFORMANCE DATA

SAE Gross HP @ 1800 RPM (60 Hz) Rated	24.8
Load Fuel Consumption (gal/Hr) Rated	0.97
Load Exhaust Gas Flow (cfm) Rated Load	109
Exhaust Gas Temperature (°F)	1005

United States EPA - Mobile Off-Highway Tier 4 Limits - 11 ≤ ~ <25 BHP

Criteria Pollutant	Emission Requirements		Certified Engine Emissions	
NOx (Oxides of Nitrogen as NO2)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
HC (Total Unburned Hydrocarbons)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
NOx + HC (Combined)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
CO (Carbon Monoxide)	4.92	gr/bhp-hr	0.82	gr/bhp-hr
PM (Particulate Matter)	0.29	gr/bhp-hr	0.08	gr/bhp-hr
NMHC (Non-Methane Hydrocarbons)	N/A	gr/bhp-hr	N/A	gr/bhp-hr
NMHC + NOx	5.59	gr/bhp-hr	4.47	gr/bhp-hr

EPA Engine Family:	LKBXL01.5FCC
EPA Certificate of Conformance:	LKBXL01.5FCC-025
ARB Executive Order:	U-R-025-0869
Effective Date:	Model Year 2020

Note: Engine operation with excessive air intake or exhaust restriction beyond factory published maximum limits, or with improper service maintenance, may result in higher emission levels.




UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
2020 MODEL YEAR
CERTIFICATE OF CONFORMITY
WITH THE CLEAN AIR ACT

OFFICE OF TRANSPORTATION
AND AIR QUALITY
ANN ARBOR, MICHIGAN 48105

Certificate Issued To: Kubota Corporation
(U.S. Manufacturer or Importer)
Certificate Number: LKBXL01.5FCC-025

Effective Date:
08/22/2019
Expiration Date:
12/31/2020


Byron J. Bunker, Division Director
Compliance Division

Issue Date:
08/22/2019
Revision Date:
N/A

Model Year: 2020
Manufacturer Type: Original Engine Manufacturer
Engine Family: LKBXL01.5FCC


Mobile/Stationary Indicator: Mobile
Emissions Power Category: 8<=kW<19
Fuel Type: Diesel
After Treatment Devices: No After Treatment Devices Installed
Non-after Treatment Devices: Engine Design Modification

Pursuant to Section 213 of the Clean Air Act (42 U.S.C. section 7547) and 40 CFR Part 1039, and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following engines, by engine family, more fully described in the documentation required by 40 CFR Part 1039 and produced in the stated model year.

This certificate of conformity covers only those new compression-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 1039 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 1039.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 1039. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 1039.

This certificate does not cover engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.



Pursuant to the authority vested in California Air Resources Board by Sections 43013, 43018, 43101, 43102, 43104 and 43105 of the Health and Safety Code; and

Pursuant to the authority vested in the undersigned by Sections 39515 and 39516 of the Health and Safety Code and Executive Order G-19-095;

IT IS ORDERED AND RESOLVED: That the following compression-ignition engines and emission control systems produced by the manufacturer are certified as described below for use in off-road equipment. Production engines shall be in all material respects the same as those for which certification is granted.

MODEL YEAR	ENGINE FAMILY	DISPLACEMENT (liters)	FUEL TYPE	USEFUL LIFE (hours)
2020	LKBXL01.5FCC	1.500	Diesel	3000
SPECIAL FEATURES & EMISSION CONTROL SYSTEMS			TYPICAL EQUIPMENT APPLICATION	
Indirect Diesel Injection			Generator Set, Light Tower, Welder, Wood Chipper	

The engine models and codes are attached.

The following are the exhaust certification standards (STD) and certification levels (CERT) for non-methane hydrocarbon (NMHC), oxides of nitrogen (NO_x), or non-methane hydrocarbon plus oxides of nitrogen (NMHC+NO_x), carbon monoxide (CO), and particulate matter (PM) in grams per kilowatt-hour (g/kw-hr), and the opacity-of-smoke certification standards and certification levels in percent (%) during acceleration (Accel), lugging (Lug), and the peak value from either mode (Peak) for this engine family (Title 13, California Code of Regulations, (13 CCR) Section 2423):


RATED POWER CLASS	EMISSION STANDARD CATEGORY		EXHAUST (g/kw-hr)					OPACITY (%)		
			NMHC	NO _x	NMHC+NO _x	CO	PM	ACCEL	LUG	PEAK
8 ≤ kW < 19	Tier 4 Final	STD	N/A	N/A	7.5	6.6	0.40	N/A	N/A	N/A
		CERT	--	--	6.0	1.1	0.11	--	--	--

BE IT FURTHER RESOLVED: That for the listed engine models, the manufacturer has submitted the information and materials to demonstrate certification compliance with 13 CCR Section 2424 (emission control labels), and 13 CCR Sections 2425 and 2426 (emission control system warranty).

Engines certified under this Executive Order must conform to all applicable California emission regulations.

This Executive Order is only granted to the engine family and model-year listed above. Engines in this family that are produced for any other model-year are not covered by this Executive Order.

Executed at El Monte, California on this 21ST day of August 2019.



Allen Lyons, Chief
 Emissions Certification and Compliance Division

